

PUBLIC ACCESSIBILITY ANALYSIS

Ontario County
20 Ontario Street
Canandaigua, NY 14424

BUILDING NAME
BUILDING ADDRESS

Ontario County Court House
27 North Main Street, Canandaigua, N.Y.

DEPARTMENT NAME

Ontario County Court House

Priority 1 - HIGH Traffic Area, Descrepancy PREVENTS Access

- There is no Van-Accessible Space.
- The running slope of the accessible path reaches 15.2%, > the max. 5.0%.
- The running slope of the ramp portion of the accessible path is 15.2%, > the max. 8.3%.
- The ramp rise without handrails is 8.75", > the max. 8".
- There is no sign at the inaccessible entrance indicating the location of the nearest accessible entrance.
- There is no International Symbol of Accessibility sign at the accessible entrance.
- The running slope outside of the main entrance is 4.0%, > the max. 2.1%.
- The elevator is 51.75" deep, < the min. 54".
- The accessible entrance does not provide direct access to the main floor, lobby and elevator.
- In Room 130 (Clerk of the Court), the clear floor space under the accessible counter is 0", < the min. 17".
- In Room 101 (Emergency Exit), the opening force of the inner door is 8 lbs, > the max. 5 lbs.
- In Room 101 (Emergency Exit), the automatic door closing time of the inner door is 1.93 sec. < the min. 5.0 sec.
- In Room 101 (Emergency Exit), the distance between the inner door and outer door is 44", < the min. 48".
- In Room 101 (Emergency Exit), the opening force of the outer door is 10 lbs, > the max. 5 lbs.
- In Room 101 (Emergency Exit), the automatic door closing time of the outer door is 2.85 sec. < the min. 5.0 sec.
- In Room 104 (Entry Lobby), the door opening force is 16 lbs, > the max. 5 lbs.

Priority 2 - LOW Traffic Area, Descrepancy PREVENTS Access

- The pathway width in the Library (Room B-16) is 29.5", < the min. 36".
- The room signs do not have raised letters.
- The room signs do not have Braille.
- The interior door handles require tight grasping, pinching and twisting of the wrist.
- In Room B-16 (Library), the clear floor space under the workspace extends 15" < the min. 17".
- In Room B-16 (Library), the height of the child's play table is 20.5", < the min. 26".
- In Room B-16 (Library), the knee space width under the child's play table is 23" < the min. 30".
- In Room B-16 (Library), the knee space height under the child's play table is 17.5" < the min. 24".
- In Room 213 (Jury Room), the opening force of the door to the South Court Room is 20 lbs, > the max. 5 lbs.
- In Room 218 (Vestibule), the door opening force is 6 lbs, > the max. 5 lbs.
- In Room 218 (Vestibule), the automatic door closer time is 3.85 sec., < the min. 5.0 sec.
- In Room 219 (Jury Room), the opening force of the door to the North Court Room is 13 lbs, > the max. 5 lbs.
- In Room 219 (Jury Room), the automatic door closer time is 2.7 sec., < the min. 5.0 sec.
- In Room 219 (Jury Room), the opening force of the door to

- In Room 104 (Entry Lobby), the automatic door closer time is 2.77 sec., < the min. 5.0 sec.
- In Room 121 (Hallway), the door opening force is 15 lbs, > the max. 5 lbs.
- In Room 121 (Hallway), the automatic door closer time is 4.93 sec., < the min. 5.0 sec.
- In Room 128 (Family Court), the door opening force is 10 lbs, > the max. 5 lbs.
- In Room 128 (Family Court), the automatic door closer time is 3.58 sec., < the min. 5.0 sec.
- In Room 129 (Surrogate Court), the door opening force is 18 lbs, > the max. 5 lbs.
- In Room 129 (Surrogate Court), the automatic door closer time is 3.78 sec., < the min. 5.0 sec.
- In Room 130 (Surrogate Court), the door opening force is 18 lbs, > the max. 5 lbs.
- In Room 130 (Surrogate Court), the automatic door closer time is 2.85 sec., < the min. 5.0 sec.
- In Room 209 (South Court), the door opening force is 10 lbs, > the max. 5 lbs.
- In Room 128 (Family Court), the door opening force is 10 lbs, > the max. 5 lbs.
- In Room 128 (Family Court), the automatic door closer time is 3.58 sec., < the min. 5.0 sec.
- In Room 128 (Family Court), the automatic door closer time is 3.58 sec., < the min. 5.0 sec.
- In Room 129 (Surrogate Court), the door opening force is 18 lbs, > the max. 5 lbs.
- In Room 129 (Surrogate Court), the automatic door closer time is 3.78 sec., < the min. 5.0 sec.
- In Room 130 (Surrogate Court), the door opening force is 18 lbs, > the max. 5 lbs.
- In Room 130 (Surrogate Court), the automatic door closer time is 2.85 sec., < the min. 5.0 sec.
- In Room 209 (South Court), the door opening force is 10 lbs, > the max. 5 lbs.
- In Room 210 (Vestibule), the swing side clearance is 6.5", < the min. 18".
- In Room 210 (Vestibule), the door opening force is 10 lbs, > the max. 5 lbs.
- In Room 210 (Vestibule), the automatic door closer time is 4.37 sec., < the min. 5.0 sec.
- In Room 210 (Vestibule), the door opening force is 14 lbs, > the max. 5 lbs.
- In Room 220 (South Court), the door opening force is 12 lbs, > the max. 5 lbs.

- the North Court is 2.7 sec., < the min. 5.0 sec.
- In Room 219 (Jury Room), the automatic closer time on the North Court door is 2.7 sec., < the min. 5.0 sec.

- In Room 220 (South Court), the automatic closer time on the door to the North Court is 4.23 sec., < the min. 5.0 sec.
- In Room 228 (Entry Lobby), the door opening force is 12 lbs, > the max. 5 lbs.
- In Room 228 (Entry Lobby), the automatic closer time on the door to the North Court is 4.23 sec., < the min. 5.0 sec.
- In Room 106 (Women's Room), the sign text characters are not raised.
- In Room 106 (Women's Room), the sign has no Braille.
- In Room 106 (Women's Room), the width of the stall is 38.5", < the min. 60".
- In Room 109 (Men's Room), the sign text characters are not raised.
- In Room 109 (Men's Room), the sign has no Braille.
- In Room 109 (Men's Room), the opening force of the door is 15 lbs, > the max. 5 lbs.
- In Room 109 (Men's Room), the automatic door closer time is 2.96 sec., < the min. 5.0 sec.
- In Room 109 (Men's Room), the width of the stall is 43.75", < the min. 60".
- In Room 211 (Men's Room), there is no sign.
- In Room 211 (Men's Room), the door width is 29", < the min. 32".
- In Room 211 (Men's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 211 (Men's Room), the clear floor space for wheelchair turn-around is 53", < the min. 60".
- In Room 212 (Women's Room), the sign does not have raised letters.
- In Room 212 (Women's Room), the sign has no Braille.
- In Room 212 (Women's Room), the door width is 29", < the min. 32".
- In Room 212 (Women's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 216 (Men's Room), there is no sign.
- In Room 216 (Men's Room), the door width is 29", < the min. 32".
- In Room 217 (Women's Room), there is no sign.
- In Room 217 (Women's Room), the door width is 29", < the min. 32".
- In Room 309 (Men's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 309 (Men's Room), the door opening force is 11 lbs, > the max. 5 lbs.
- In Room 309 (Men's Room), the automatic door closing time is 2.71 sec.,

< the min. 5.0 sec.

- In Room 311 (Women's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 311 (Women's Room), the door opening force is 10 lbs, > the max. 5 lbs.
- In Room 311 (Women's Room), the stall lock requires tight grasping, pinching and twisting of the wrist.
- In Room 311 (Women's Room), the width of the stall is 39", < the min. 60".

Priority 3 - HIGH Traffic Area, Descrepancy IMPEDES Access

- The width of Space 2 is 7' 7.5", < the min. 8'.
- The width of Space 3 is 7' 6", < the min. 8'.
- The width of Space 4 is 7' 8", < the min. 8'.
- The width of Space 5 is 7' 8", < the min. 8'.
- The cross slope of Space 3 is 3.4%, > the max. 2.1%.
- The cross slope of Aisle 2 is 4.2%, > the max. 2.1%.
- The cross slope of Space 4 is 3.5%, > the max. 2.1%.
- The cross slope of Space 5 is 3.6%, > the max. 2.1%.
- The cross slope of Aisle 3 is 4.7%, > the max. 2.1%.
- There is no ADA Sign at Spaces 1 & 2. Instead there is a sign at Aisle 1.
- The soda and candy vending controls are 49.5" and 54" > the max. 48".
- In Room 129 (Surrogate Court), the clear floor space under the workspace extends 16" < the min. 17".
- In Room 128 (Family Court), the knee space under the workspace is 25" < the min. 27".
- In Room 314 (Family Court), the knee space under the workspace is 25" < the min. 27".
- In Room 129 (Surrogate Court), the accessible counter length is 29", < the min. 36".
- In Room 130 (Clerk of the Court), the accessible counter length is 30", < the min. 36".
- In Room 130 (Clerk of the Court), the accessible counter depth is 24", < the main counter depth of 30".
- In Room 129 (Surrogate Court), the clear floor space under the accessible counter is 6", < the min. 17".
- In Room 123 (Court Room), the sign height is 37.5", < the min. 40".

Priority 4 - LOW Traffic Area, Descrepancy IMPEDES Access

- The room signs are not mounted on the latch side of the door.
- In Room 214 (Meeting Room), the clear floor space under the workspace extends 15" < the min. 17".
- In Room B-15 (Matrimony Screening), the knee space under the workspace is 26" < the min. 27".
- In Room B-16 (Library), the knee space under the workspace is 26" < the min. 27".
- In Room 214 (Meeting Room), the knee space under the workspace is 25" < the min. 27".
- In Room 219 (Jury Room), the knee space under the workspace is 25.5" < the min. 27".
- In Room B-19 (Conference Room), the coat rack height is 61", > the max. 48".
- In Room 120 (Holding Cell), the swing side clearance of the door to Room 122 is 9", < the min. 18".
- In Room 120 (Holding Cell), the swing side clearance of the door to Room 121 is 7", < the min. 18".
- In Room 122 (Hall to Holding Cell), the swing side clearance is 8", < the min. 18".
- In Room 124 (Hearing Magistrate), the sign height is 38.5", < the min. 40".
- In Room 124 (Hearing Magistrate), the swing side clearance is 8.5", < the min. 18".
- In Room 124 (Hearing Magistrate), the door opening force is 9 lbs, > the max. 5 lbs.

- In Room 123 (Court Room), the swing side clearance is 12", < the min. 18".
- In Room 128 (Family Court), the sign height is 64", > the max. 60".
- In Room 128 (Family Court), the knee space under the workspace is 25" < the min. 27".
- In Room 129 (Surrogate Court), the sign height is 37.5", < the min. 40".
- In Room 129 (Surrogate Court), the clear floor space depth is 16" < the min. 17".
- In Room 128 (Family Court), the sign height is 64", > the max. 60".
- In Room 128 (Family Court), the knee space under the workspace is 25" < the min. 27".
- In Room 129 (Surrogate Court), the sign height is 37.5", < the min. 40".
- In Room 129 (Surrogate Court), the clear floor space depth is 16" < the min. 17".
- In Room 228 (Entry Lobby), the door opening force is 12 lbs, > the max. 5 lbs.
- In Room 228 (Entry Lobby), the automatic closer time on the door to the North Court is 4.23 sec., < the min. 5.0 sec.
- In Room 106 (Women's Room), the sign is not mounted on the latch side of the door.
- In Room 106 (Women's Room), the sign does not have 18" by 18" swing side clearance.
- In Room 106 (Women's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 106 (Women's Room), the opening force of the door is 11 lbs, > the max. 5 lbs.
- In Room 106 (Women's Room), the automatic door closer time is 2.96 sec., < the min. 5.0 sec.
- In Room 106 (Women's Room), the coat hook height is 63.75", > the max. 48".
- In Room 106 (Women's Room), the pipes under the lavatory are not insulated or encased.
- In Room 106 (Women's Room), the height of operable parts of the towel dispenser is 56.5", > the max. 44".
- In Room 106 (Women's Room), the height of side grab bar is 36.5" > the max. 36".
- In Room 106 (Women's Room), there is no rear grab bar.
- In Room 106 (Women's Room), the width of the stall door opening is 31", < the min. 32".
- In Room 106 (Women's Room), the stall door is not self closing.

- In Room 125 (Court Clerk), the sign height is 38.5", < the min. 40".
- In Room 125 (Court Clerk), the coat hook height is 81", > the max. 81".
- In Room 124 (Hearing Magistrate), the swing side clearance is 8.5", < the min. 18".
- In Room 214 (Meeting Room), the coat hook is 58" high, > the max. 48".
- In Room 219 (Jury Room), the coat rack height is 58", > the max. 48".
- In Room 227 (Holding Cell), the swing side clearance is 3.5" < the min. 18".
- In Room 227 (Holding Cell), the transom height is 1.0", > the max. 0.75".

- In Room 106 (Women's Room), there are not pulls on both sides of stall door.
- In Room 109 (Men's Room), the sign does not have 18" by 18" swing side clearance.
- In Room 109 (Men's Room), the sign height is 84", > the max. 60".
- In Room 109 (Men's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 109 (Men's Room), the coat hook height is 65.5", > the max. 48".
- In Room 109 (Men's Room), the pipes under the lavatory are not insulated or encased.
- In Room 109 (Men's Room), the height of operable parts of the towel dispenser is 58", > the max. 44".
- In Room 109 (Men's Room), the toilet clearance from the side wall is 43.75", < the min. 60".
- In Room 109 (Men's Room), the height of the toilet seat is 20", > the max. 19".
- In Room 109 (Men's Room), the height of side grab bar is 36.5", > the max. 36".
- In Room 109 (Men's Room), there is no rear grab bar.
- In Room 109 (Men's Room), the flush activating force is 6 lbs, > the max. 5 lbs.
- In Room 109 (Men's Room), the flush control is not on the open side of the water closet.
- In Room 109 (Men's Room), the width of the stall door opening is 31", < the min. 32".
- In Room 109 (Men's Room), the stall door is not self closing.
- In Room 109 (Men's Room), there are not pulls on both sides of the stall door.
- In Room 211 (Men's Room), the clear floor space beyond the swing of the door is < the min. 30" x 48".
- In Room 211 (Men's Room), the clear floor space under the lavatory is 16", < the min. 17".
- In Room 211 (Men's Room), the pipes under the lavatory are not insulated or encased.
- In Room 211 (Men's Room), the height of operable parts of the towel dispenser is 57", > the max. 44".
- In Room 211 (Men's Room), the force required to activate the towel dispenser is 7 lbs., > the max. 5 lbs.
- In Room 211 (Men's Room), the centerline of the toilet seat is 14" from the

side wall, < the min. 16".

- In Room 211 (Men's Room), the toilet clearance from the side wall is 54", < the min. 60".
- In Room 211 (Men's Room), there is no side grab bar.
- In Room 211 (Men's Room), there is no rear grab bar.
- In Room 211 (Men's Room), the flush control is not on the open side of the water closet.
- In Room 211 (Men's Room), the toilet paper dispenser is 6" from the toilet seat, < the min. 7".
- In Room 212 (Women's Room), the sign does not have 18" by 18" swing side clearance.
- In Room 212 (Women's Room), the sign height is 67", > the max. 60".
- In Room 212 (Women's Room), the clear floor space for wheelchair turn-around is 53", < the min. 60".
- In Room 212 (Women's Room), the clear floor space beyond the swing of the door is < the min. 30" x 48".
- In Room 212 (Women's Room), the clear floor space under the lavatory is 16" < the min. 17".
- In Room 212 (Women's Room), the pipes under the lavatory are not insulated or encased.
- In Room 212 (Women's Room), the activating force of the faucet is 17 lbs, > the max. 5 lbs.
- In Room 212 (Women's Room), the height of operable parts of the towel dispenser is 58", > the max. 44".
- In Room 212 (Women's Room), the force required to activate the towel dispenser is 7 lbs., > the max. 5 lbs.
- In Room 212 (Women's Room), the centerline of the toilet seat is 18.5" from the side wall, > the max. 18".
- In Room 212 (Women's Room), the toilet clearance from the side wall is 54", < the min. 60".
- In Room 212 (Women's Room), there is no side grab bar.
- In Room 212 (Women's Room), there is no rear grab bar.
- In Room 212 (Women's Room), the toilet paper dispenser is 6" from the toilet seat, < the min. 7".

- In Room 216 (Men's Room), the door swing side clearance is 16", < the min. 18".
- In Room 216 (Men's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 216 (Men's Room), the clear floor space for wheelchair turn-around is 53", < the min. 60".
- In Room 216 (Men's Room), the clear floor space beyond the swing of the door is < the min. 30" x 48".
- In Room 216 (Men's Room), the clear floor space under the lavatory is 16", < the min. 17".
- In Room 216 (Men's Room), the height of the lavatory is 34.5", > the max. 34".
- In Room 216 (Men's Room), the pipes under the lavatory are not insulated or encased.
- In Room 216 (Men's Room), the height of operable parts of the towel dispenser is 57", > the max. 44".
- In Room 216 (Men's Room), the force required to activate the towel dispenser is 7 lbs., > the max. 5 lbs.
- In Room 216 (Men's Room), the centerline of the toilet seat is 14" from the side wall, < the min. 16".
- In Room 216 (Men's Room), the toilet clearance from the side wall is 53.5", < the min. 60".
- In Room 216 (Men's Room), there is no side grab bar.
- In Room 216 (Men's Room), there is no rear grab bar.
- In Room 216 (Men's Room), the flush control is not on the open side of the water closet.
- In Room 216 (Men's Room), the toilet paper dispenser is 6" from the toilet seat, < the min. 7".
- In Room 217 (Women's Room), the door swing side clearance is 15", < the min. 18".
- In Room 217 (Women's Room), the door handle requires tight grasping, pinching and twisting of the wrist.
- In Room 217 (Women's Room), the clear floor space for wheelchair turn-around is 53", < the min. 60".
- In Room 217 (Women's Room), the clear floor space beyond the swing of the door is < the min. 30" x 48".

- In Room 217 (Women's Room), the clear floor space under the lavatory is 16", < the min. 17".
- In Room 217 (Women's Room), the height of the lavatory is 34.25", > the max. 34".
- In Room 217 (Women's Room), the pipes under the lavatory are not insulated or encased.
- In Room 217 (Women's Room), the height of operable parts of the towel dispenser is 57", > the max. 44".
- In Room 217 (Women's Room), the force required to activate the towel dispenser is 7 lbs., > the max. 5 lbs.
- In Room 217 (Women's Room), the centerline of the toilet seat is 14" from the side wall, < the min. 16".
- In Room 217 (Women's Room), the toilet clearance from the side wall is 54", < the min. 60".
- In Room 217 (Women's Room), there is no side grab bar.
- In Room 217 (Women's Room), there is no rear grab bar.
- In Room 217 (Women's Room), the toilet paper dispenser is 5" from the toilet seat, < the min. 7".
- In Room 309 (Men's Room), the threshold height is 5/8", > the max. 1/2".
- In Room 309 (Men's Room), the height of the mirror is 40.5", > the max. 40".
- In Room 309 (Men's Room), the rear grab bar extends 18" toward the open side, < the min. 24".
- In Room 309 (Men's Room), the stall door is not self closing.
- In Room 311 (Women's Room), the threshold height is 5/8", > the max. 1/2".
- In Room 311 (Women's Room), the clear floor space between the door and the privacy wall is 23", < the min. 24".
- In Room 311 (Women's Room), the height of the mirror is 40.25", > the max. 40".
- In Room 311 (Women's Room), the coat hook height is 65", > the max. 48".
- In Room 311 (Women's Room), the clear floor space under the lavatory is 7", < the min. 17".
- In Room 311 (Women's Room), the pipes under the lavatory are not insulated or encased.
- In Room 311 (Women's Room), the centerline of the toilet seat is 19.5" from the side wall, > the max. 18".

- In Room 311 (Women's Room), the height of the side grab bar is 36.75", > the max. 36".
- In Room 311 (Women's Room), there is no rear grab bar.
- In Room 311 (Women's Room), the force required to activate the towel dispenser is 7 lbs., > the max. 5 lbs.
- In Room 311 (Women's Room), the flush control is not on the open side of the water closet.
- In Room 311 (Women's Room), the toilet clearance from the side wall is 54", < the min. 60".
- In Room 311 (Women's Room), the toilet paper dispenser is 10" from the toilet seat, > the min. 9".
- In Room 311 (Women's Room), the stall door width is 31.5", < the min. 32".
- In Room 311 (Women's Room), the stall door is not self closing.
- In Room 311 (Women's Room), there aren't pulls on both sides of the stall door.
- In Room B-1 (Basement Hallway), the activating force of the drinking fountain is 8 lbs., > the max. 5 lbs.
- In Room B-1 (Basement Hallway), the height of the spout outlet is 38.5", > the max. 36".
- In Room B-1 (Basement Hallway), the distance of the spout outlet from the rear of the fountain is 11.5", < the min. 15".
- In Room B-1 (Basement Hallway), the distance of the spout outlet from the front of the fountain is 6", > the max. 5".
- In Room B-1 (Basement Hallway), the distance the drinking fountain protrudes 13.5", > the max. 4".
- In Room 102 (First Floor Hallway), the activating force of the drinking fountain is 6 lbs, > the max. 5 lbs.
- In Room 102 (First Floor Hallway), the height of the drinking fountain spout is 38", > the max. 36".
- In Room 102 (First Floor Hallway), the distance of the spout outlet from the rear of the drinking fountain is 11.5", < the min. 15".
- In Room 102 (First Floor Hallway), the distance of the spout outlet from the front of the drinking fountain is 6", > the max. 5".
- In Room 102 (First Floor Hallway), the distance the drinking fountain protrudes 13", > the max. 4".

- In Room 107 (Phone Hallway), the height of the highest operable part of the pay phone is 61", > the max. 48".
- In Room 107 (Phone Hallway), the distance the pay phone protrudes 7", > the max. 4".
- In Room 107 (Phone Hallway), the pay phone does not have teletype (TTY).
- In Room 204 (South Court Entry Hallway), the activating force of the drinking fountain is 10 lbs, > the max. 5 lbs.
- In Room 204 (South Court Entry Hallway), the height of the spout outlet is 39", > the max. 36".
- In Room 204 (South Court Entry Hallway), the distance of the spout outlet from the front of the fountain is 6", > the max. 5".
- In Room 228 (North Court Entry Lobby), the activating force of the drinking fountain is 10 lbs., > the max. 5 lbs.
- In Room 228 (North Court Entry Hallway), the height of the spout outlet is 39", > the max. 36".
- In Room 228 (North Court Entry Hallway), the distance of the spout outlet from the rear of the fountain is 14.25", < the min. 15".